

13	The ambient air temperature			<40 deg C					
14	Its average value measured over a period of 24 Hrs.	Enumerable	Mandatory	<35 deg C					
15	The minimum ambient air temperature	Enumerable	Golden, Filter, Mandatory	minus 5 deg C	minus 20 deg C				
16	The altitude	Enumerable	Mandatory	<1000 m					
17	The ambient air is not materially polluted by dust, smoke, corrosive or flammable gases and vapours, or salt	Enumerable	Mandatory	Yes					
18	The average value of relative humidity measured over a period of 24 Hrs.	Enumerable	Mandatory	<95%					
19	The average value of relative humidity measured during a period of one month	Enumerable	Mandatory	<90%					
20	GROUP: CERTIFICATIONS								
21	Availability of type test reports from any Central Govt. laboratory / ILAC approved laboratory / NABL aproved laboratory. Type test report shall be complete alongwith authenticated drawings from the test lab	Enumerable	Mandatory	Yes					
22	Type Test Report Number	Text	Mandatory						
23	Type Test Report Date	Text	Mandatory						
24	Name of testing lab	Text	Mandatory						
25	Address of testing lab	Text	Mandatory						
26	All the test reports shall be furnished as and when requested to do so by Purchase authority	Enumerable	Mandatory	Yes					